

Z-PC Line

EN **Z-3AO**
Modbus module with three 12 bit ANALOG OUTPUTS.

Installation Manual

- Contents:**
- General Specifications
 - Technical Specifications
 - Modbus connections rules
 - Installation rules
 - Electrical connections
 - DIP-switches settings
 - Modbus basic register and LEDs signalings
 - Factory Settings and advanced setting



SENECA s.r.l.
 Via Germania, 34 - 35127 - Z.I. CAMIN - PADOVA - ITALY
 Tel. +39.049.8705355 - 8705359 - Fax +39.049.8706287
 For manuals, and configuration software, see www.seneca.it

This document is property of SENECA srl. Duplication and reproduction are forbidden, if not authorized. Contents of the present documentation refers to products and technologies described in it. All technical data contained in the document may be modified without prior notice. Content of this documentation is subject to periodical revision.

GENERAL SPECIFICATIONS

- 3 settable analog outputs in voltage or current with 12 bit resolution.
- Bipolar voltage outputs with settable full scale and start scale at -10...10 V, 0...10 V or 2...10 V.
- Current outputs outputs with settable full scale and start scale at 0...20 mA or 4...20 mA.
- 1500 Vac output isolation compared with other low voltage circuits.
- Outputs protected with 400 W/ms transient current suppressors; user load protection by PTC.
- Connection with shared negative pole.
- Removable terminals with section of 2.5 mm².
- Analogue output response time: 400 ms (10-90%); typical < 50 ms.
- Easy connections for power supply and serial communications from seneca bus installable to the standards DIN 46277 rail.
- RS485 serial communication with Modbus-Rtu protocol, maximum 64 nodes.
- Communication and also programming from front Jack 3,5 mm connector with RS232 Modbus protocol.
- Module insertion or extraction from seneca bus without interruptions for communication and power supply.
- Communication time below 10 ms (@ 38400 Baud).
- Connection distance up to 1200 m.
- Set the Modbus address and the Baud rate with DIP-Switch.

TECHNICAL SPECIFICATIONS

Outputs	
Voltage output	-10...10 V, 0...10 V, 2...10 V, pilotable impedance > 600 Ω
Current output	0...20 A, 4...20 A, pilotable impedance < 600 Ω
Number channels	3
Voltage output resolution	12 bit (5 mV)
Current output resolution	12 bit (5 μA)
Voltage output errors	Calibration: 0.2% del F.S. max, 0.1% typical Linearity: 0.05% del F.S. Thermal stability: 0.01%/°C del F.S.
Current voltage errors	Calibration: 0.2% del F.S. max, 0.1% Typical Linearity: 0.05% del F.S. Thermal stability: 0.01%/°C del F.S.

Power supply	
Voltage	10...40 V _{DC} 19...28 V _{AC} @ 50...60 Hz
Consumption	Typical: 1,5 W, Maximum: 3,2 W
Environmental condition	
Temperature	-10...+65°C (-10...+55°C UL)
Humidity	30...90% a 40°C non condensing
Altitude	Up to 2000 m a.s.l.
Storage Temperature	-20...+85°C
Protection	IP20
Connections	
Connections	Removable 3-way crew terminals, 5,08 pitch Rear IDC10 connector for DIN 46277 rail Frontal jack 3.5 mm


Box / Dimensions	
Dimensioni	L: 100 mm; H: 112 mm; W: 17,5 mm
Box	PBT, Black

Isolations 1500 V	
Standards	
The module complies with the following standards:	
	EN61000-6-4/2002-10 (electromagnetic emission, industrial environment).
	EN61000-6-2/2006-10 (electromagnetic immunity, industrial environment)
	EN61010-1/2001 (safety). All circuits must be isolated from the other circuits under dangerous voltage with double isolation. The power supply transformer must comply with EN60742: "isolated transformers and safety transformers".

ADDITIONAL NOTES:
 Use in Pollution Degree 2 Environment.
 Power Supply must be Class 2.
 When supplied by an Isolated Limited Voltage/Limited Current power supply a fuse rated max 2.5A shall be installed in the field.

MODBUS CONNECTIONS RULES


- 1) Connect the module into the DIN rail (max 120)
- 2) Use a suitable length cable to connect the remote modules. In the table below the relative data to the length of the bus and length of the cable are reported.
 -Bus length: Maximum length of the Modbus network. The bus length is determined from the length of network that has the two modules who has been switched on the bus terminator. (see scheme 1).
 -Drop length: Maximum length of branch (see scheme 1).



For the maximum performances it's recommended to use a specific shielded cable, as an example BELDEN 9841.

INSTALLATION RULES


The module is designed to be installed, in vertical position, on DIN 46277 rail. For the best performance and long life cycle the cables raceways and other objects in the control panel must be placed not to obstruct the slits of the module that must be ventilated. Never install the modules near heat sources. It's advised the installation of the module in the lower part of the control panel.




ELECTRICAL CONNECTIONS

Power supply and Modbus interface


From IDC10 (rear connector of the module) or Z-PC-DINAL2-17,5 (optional) are available power supply and Modbus interface. In the next page are shown the use specifications of IDC10 and Z-PC-DINAL2-17,5.




In the figure the meaning of the IDC10 connector pins is showed. This connector can be used in alternative to the screw terminals blocks




If Z-PC-DINAL2-17,5 accessory is used, the power supply signals and communication signals may be provided by the terminals block into the DIN rail support. In the figure are shown the meaning and the position of the terminal blocks. The DIP-switch that set the 120 Ω terminator is used only for CAN communication. GNDSHLD: Shield to protect the connection cables (recommended).



10, 11 and 12 screw terminals are internally connected between them. To 7, 8 and 9 screw terminals are available the analog outputs, they can be set from DIP-switches.



Screw terminal 2 and 3 are the alternative to seneca DIN rail bus to provide the power supply at the module. **The upper limits must not be exceeded as this can seriously damage the module.** If the power supply source is not protected against overload, a safety fuse with a maximum permissible value of 2.5 A must be installed in the power supply line.




Connection for RS485 communication using the Modbus master system as an alternative to the Z-PC-DINx bus. Note: the indication of the RS485 connection polarity is not standardised and in some masters may be inverted.

RS232

The RS232 port can be used to communicate and also to program the module. Z-NET or EASY Z-PC are the Seneca configurations softwares. The RS232 communication use the following parameter of communications:

2400,8,N,1

RS232 and RS485 port use the same Modbus protocol. When RS232 communication is active, the serial RS485 bus network will be stopped. The RS485 will return automatically active a few seconds after the last data packed received from RS232. The 3,5 mm DB9 jack stereo connector for RS232 communication can either be assembled as indicated in the following figure or purchased as an accessory (cod. PM001601).



DIP-SWITCHES SETTING

The DIP-switches positions defines the Modbus communication parameter: Address and Baud rate. In the following table the Baud rate and address value are listed as a function of the DIP-switches position:

DIP-switches table					
POSITION	BAUD RATE	POSITION	ADDRESS	POSITION	TERMINATOR
00xxxxxx	9600	xx000001	# 1	none	see TERM
01xxxxxx	19200	xx000010	# 2	none	see TERM
10xxxxxx	38400		
11xxxxxx	57600	xx111111	# 63		

POSITION	BAUD RATE	POSITION	ADDRESS
xx000000	From EEprom	xx000000	From EEprom

Note: when DIP-switches from 3 to 8 are in OFF, communication settings are retrieved from EEprom

Note 2: The termination of RS485 communication must be enabled only to the ends of the communication line.

RS485 line termination




The RS485 line must be terminated only at the ends of the communication network line.

Output setting from DIP-switches

In a side of the module there are three DIP-switches that let to choose, for each channel, the voltage or current output. The output choice (if voltage or current) is automatically recognized by the module.

Recommended to set the DIP-switches when the module is off.



MODBUS BASIC REGISTER AND LED SIGNALINGS

Holding register

Registers	Name	Description
40005	OUT CH 1	Analogue output value: the acceptable values are from 0 to 10000 for current output in 0...20 mA, 4...20 mA or -10000 to -10000 with corresponding voltage output in 0...10 V or 2...10 V depending on the status of the EPRFLG register flags. The value memorised in EEPROM will be used as a default value when the unit is switched on and at the end of the timeout if the safety function is enabled (see USER MANUAL).
40006	OUT CH 2	As above
40007	OUT CH 3	As above

LEDs signalings

LED	STATE	Meaning of LEDs
PWR	On	Power supply presence.
FAIL	Blinking	Error settings.
	On	Fault/failure.
RX	Blinking	Recived data.
	On	Error connection.
TX	Blinking	Recived data.

FACTORY SETTING AND ADVANCED SETTING

Factory settings

- All DIP-switch in OFF position:**
- Modbus protocol: - Communication parameters: 38400 8,N,1 Addr. 1
 - Output channel 1 : VOLTAGE ± 10 V
 - Output channel 2 : VOLTAGE ± 10 V
 - Output channel 3 : VOLTAGE ± 10 V
 - Time out : DISABLE

Advanced settings

- Set the outputs SS (Start scale) and the FS (full scale).
- Set a safety timer to regulate the time that the outputs will be set in the safety state.
- Set the outputs safety state that will be enabled in case of lost communication for a time equal to settled safety timer.

Variations of standard parameters are possible by using configuration softwares Z-NET and EASY-Z-PC (www.seneca.it). For more information about a list of all register and their function consult the USER manual

